



Ivins City
 55 N. Main St.
 Ivins, UT
 84738

IRC EQUIPMENT AND DUCT PLAN

IRC – M1401.3 Sizing

Heating and cooling *equipment* and *appliances* shall be sized in accordance with ACCA Manual S based on building loads calculated in accordance with ACCA Manual J or other *approved* heating and cooling calculation methodologies.

IRC – M1601.1 Duct Design

Duct systems serving heating, cooling and ventilation equipment shall be installed in accordance with the provisions of this section and ACCA Manual D or other *approved* methods.

Installers Company:	Phone #	
License #	Permit #	
Subdivision:	Lot #	Phase #
Address:		

I hereby certify that the heating and cooling equipment, appliances and ducts are sized and designed in accordance with ACCA Manual J for heating and cooling loads, ACCA Manual S for equipment sizing and ACCA Manual D for duct sizing or other *approved* calculation methodologies.

Installer’s signature: _____ Date: _____

Please print your name: _____

Approved by: Building Inspector	Comments:
--	-----------

